



# CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO.: CQC22024343784

Valid from: Jul.04,2022

Valid until:long-term

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Fujian Super Power New Energy Co., LTD. F-01 Block, Tongyou Industrial Park, Wuyi New District, Nanping City, Fujian Province, 354200, P.R. China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Fujian Super Power New Energy Co., LTD. F-01 Block, Tongyou Industrial Park, Wuyi New District, Nanping City, Fujian Province, 354200, P.R. China
NAME AND LOCATION OF THE FACTORY	Fujian Super Power New Energy Co., LTD. 3#, 4#, F-01 Block, Tongyou Industrial Park, Wuyi New District, Nanping City, Fujian Province, 354200, P.R. China
PRODUCT NAME, MODEL AND SPECIFICATION	Energy Type Battery Cluster CL1001A360 ( See Appendix )
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 36276-2018
TYPE OF CERTIFICATION SCHEMES	Product Testing + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC13-464225-2018.  
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



# CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO. : CQC22024343784

page 1 of 1

paper:

This certificate and attachments shall be used at the same time, and the verification instructions can be found in the main certificate.

充电截止电压 ( V )	1296	电池簇额定充电功率 ( kW )	129.6
放电截止电压 ( V )	1008	电池簇额定放电功率 ( kW )	129.6
标称电压 ( V )	1152	电池簇额定充电容量 ( Ah )	450
充电电流 ( A )	225	电池簇额定放电容量 ( Ah )	450
放电电流 ( A )	225	电池簇型号	CL1001A360
最大充电电流 ( A )	450	最大放电电流 ( A )	450
电池单体告警温度 ( °C )	55	电池单体保护温度 ( °C )	60



CHINA QUALITY CERTIFICATION CENTRE